

PAT Report RCDs

For all Sites and Locations



CLIENT DETAILS	
Company Name:	RSR Systems Ltd
Address:	Waterside House Falmouth Road Penryn Cornwall TR10 8BE

DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING			
Company Name:	PAT Serve Electrical Safety		
Address:	Waterside House Falmouth Road Penryn Cornwall TR10 8BD	Telephone:	01326 378268
		Mobile:	0777 9999999
		Email:	support@simplypats.co.uk
Order Number:	RSR0001/FEB	Signature:	<i>Your Signature</i>
File Name:	Example File.PAT		

RCD DETAILS AND TEST RESULTS					
Key P = PASS / F = FAIL / S = SKIP (or test not applicable)					
Appliance Id	Appliance Description	Test Date	RCD Result mS	RCD Ouput mA	Status
BUILDING 1 - ROOM 1					
AP0020	RCD	04/02/2011	1.00	30 mA	P
AP0026	RCD	04/02/2011	2.00	30 mA	P
Total Appliances >					2