

Current Appliance E01079779



CLIENT DETAILS	
Company Name:	RSR Systems Ltd
Address:	Waterside House Falmouth Road Penryn Cronwall TR10 8BD

DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING	
Company Name:	SimplyPats PAT Testing
Address:	Waterside House Falmouth Road Penryn Cornwall TR10 8BD
Telephone:	01326 378268
Mobile:	07775 000000
Email:	support@simplypats.co.uk
Order Number:	RSR/0001
File Name:	Example File.PAT
Signature:	<i>Your Signature</i>

For Appliance: E01079779					
Appliance Id:	E01079779	Test Date:	01/02/2011	Time:	10:18
Appliance:	PAPER SHREDDER	Retest Period:	12	Retest Date:	01/02/2012
Appliance SN:	4458221/22564	Class:	I	Fuse Rating:	13 Amps
Site:	RSR SYSTEMS	PAT Serial No:	010101/2421		
Location:	RECEPTION OFFICE	User:	R GARWOOD		

Key	Optional / Additional Tests							Other Tests				
	Visual Polarity	Voltage	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Touch Leakage (mA)	Sub Leakage (mA)	Flash (mA)	Clamp (mA)	Microwave (mW/cm2)	RCD Trip Time (mS)
P = PASS / F = FAIL / S = SKIP (or test not applicable)												
Result	—	—	0.08	50.00	0.40	<0.10					0.00	0.00
Limit	—	—	0.00	0.00	—	0.00	0.00	0.00	0.00	0.00		
Output	—	—	0.00	0.00	—	0.00	0.00	0.00	0.00	—	—	
Status	P S	—	P	P	P	P	S	S	S	S		

Fail Reason:

Overall Status: **PASS**

OTHER INFORMATION RELATING TO APPLIANCE OR WORK CARRIED OUT	
Test Price:	Portable Appliance
Repair Description	Qty
Labour for minor repairs	1 Minutes
Rewire existing plug	
Extra Notes	
INFORMED CLIENT OF SAFETY SWITCH ISSUE	