

PAT Report RCDs

For all Sites and Locations



CLIENT DETAILS	
Company Name:	SimplyPats
Address:	Waterside House Falmouth Road Penryn Cornwall TR10 8BD

DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING	
Company Name:	RSR Systems
Address:	Waterside House Falmouth Road Address 3 Penryn Cornwall TR10 8BD
Telephone:	01326 378268
Fax:	01326 378268
Email:	support@simplypats.co.uk
Signature:	<i>Your Signature</i>
Order Number:	
File Name:	Example File.PAT

RCD DETAILS AND TEST RESULTS					
Key P = PASS / F = FAIL / S = SKIP (or test not applicable)					
Appliance Id	Appliance Description	Test Date	RCD Result mS	RCD Ouput mA	Status
DONCASTER - KITCHEN					
2094754	RCD	11/03/2011	150.00	30 mA	P
2094755	RCD	11/03/2011	100.00	30 mA	P
2094756	RCD TRIP TIME NOT WITHIN LIMIT. DISCARD	11/03/2011	500.00	30 mA	F
2094757	RCD	11/03/2011	100.00	30 mA	P
Total Appliances >					4