

PAT Report Visual Only

For all Sites and Locations



CLIENT DETAILS	
Company Name:	SimplyPats
Address:	Waterside House Falmouth Road Penryn Cornwall TR10 8BD

DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING	
Company Name:	RSR Systems
Address:	Waterside House Falmouth Road Address 3 Penryn Cornwall TR10 8BD
Telephone:	01326 378268
Fax:	01326 378268
Email:	support@simplypats.co.uk
Signature:	<i>Your Signature</i>
Order Number:	
File Name:	Example File.PAT

APPLIANCE DETAILS AND TEST RESULTS				
Appliance Id	Appliance Description	Test Date	Retest Date	Visual Test
DONCASTER - KITCHEN				
2094740	TOASTER	23/02/11	23/02/12	Fail
DAMAGED FLEX - REWIRE WITH NEW FLEX OR DISCARD DISCARD				
				Total Appliances > 1
DONCASTER - SERVER				
2094741	SERVER	23/02/11	23/02/12	Pass
VISUAL TEST ONLY - COULD NOT SWITCH SERVER OFF				
				Total Appliances > 1
DONCASTER - OFFICE 2				
2094742	SERVER	23/02/11	23/02/12	Pass
VISUAL TEST ONLY - COULD NOT SWITCH SERVER OFF				
				Total Appliances > 1
DONCASTER - OFFICE 1				
2094743	MONITOR TANDBERG	23/02/11	23/02/12	Pass
ASKED NOT TO DISCONNECT				
				Total Appliances > 1
DONCASTER - RECEPTION				
2094744	ROATARY MOTOR	23/02/11	23/02/12	Fail
DAMAGED FLEX - REWIRE WITH NEW FLEX OR DISCARD DISCARD.				
				Total Appliances > 1
DONCASTER - MAIN OFFICE				
2094745	PRINTER	23/02/11	23/02/12	Fail
ASKED NOT TO REPAIR AS IT IS DUE TO BE REPLACED				

APPLIANCE DETAILS AND TEST RESULTS

Appliance Id	Appliance Description	Test Date	Retest Date	Visual Test
2094746	PHOTOCOPIER DAMAGED FLEX - REWIRE WITH NEW FLEX OR DISCARD ASKED NOT TO REPAIR AS DUE TO BE REPLACED	23/02/11	23/02/12	Fail

Total Appliances > 2

Total Appliances For Report: 7