

# PAT Report Passes And Fails For all Sites and Locations



CLIENT DETAILS	
Company Name:	SimplyPats
Address:	Waterside House Falmouth Road Penryn Cornwall TR10 8BD

DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING	
Company Name:	RSR Systems
Address:	Waterside House Falmouth Road Address 3 Penryn Cornwall TR10 8BD
Telephone:	01326 378268
Fax:	01326 378268
Email:	support@simplypats.co.uk
Signature:	<i>Your Signature</i>
Order Number:	
File Name:	Example File.PAT

## APPLIANCE DETAILS AND TEST RESULTS

**Key**  
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
<b>DONCASTER - KITCHEN</b>									
2094658	WATER CHILL AQUATOR	23/02/11	P	S	P 0.10	P 50.00	P 0.51	P <0.10	PASS
2094659	KETTLE LEAD	23/02/11	P	P	P 0.08	P 50.00	S	S	PASS
2094660	KETTLE JUG HADEN2	23/02/11	P	S	P 0.10	P 50.00	P 1.86	P <0.10	PASS
2094661	COFFEE MAKER BOSCH	23/02/11	P	S	S	P 50.00	P <0.05	P <0.10	PASS
2094662	REFRIGERATOR ZANUSSI	23/02/11	P	S	P 0.15	P 50.00	P <0.05	P <0.10	PASS
2094663	LEAD	23/02/11	P	P	P 0.08	P 50.00	S	S	PASS
2094665	LEAD	23/02/11	P	P	P 0.11	P 50.00	S	S	PASS
2094740	TOASTER	23/02/11	F	S	S	S	S	S	FAIL
DAMAGED FLEX - REWIRE WITH NEW FLEX OR DISCARD DISCARD									
2094750	MICROWAVE	23/02/11	P	S	P 0.09	P >199.9	P <0.05	P <0.10	PASS
2094751	MICROWAVE	23/02/11	P	S	P 0.09	P >199.9	P <0.05	P <0.10	PASS
2094752	MICROWAVE	23/02/11	P	S	P 0.10	P 50.00	P 0.05	P 0.10	FAIL
EARTH CONTINUITY FAIL - REWIRE / SERVICE / REPAIR OR DISCARD									
2094753	MICROWAVE	23/02/11	P	S	P 0.10	P >199.9	P <0.05	P 0.10	PASS
2094754	RCD	11/03/11	S	S	S	S	S	S	PASS
2094755	RCD	11/03/11	S	S	S	S	S	S	PASS
2094756	RCD	11/03/11	S	S	S	S	S	S	FAIL
TRIP TIME NOT WITHIN LIMIT. DISCARD									
2094757	RCD	11/03/11	S	S	S	S	S	S	PASS

Total Appliances > 16

## DONCASTER - MAIN OFFICE

2094697	LEAD	23/02/11	P	P	P 0.10	P 50.00	S	S	PASS
---------	------	----------	---	---	--------	---------	---	---	------

**APPLIANCE DETAILS AND TEST RESULTS**
**Key**

P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
2094698	MONITOR LCD FUJITSU SIEMENS	23/02/11	P	S	P 0.20	P 50.00	P <0.05	P 0.60	PASS
2094699	LEAD	23/02/11	P	P	P 0.04	P 49.18	S	S	PASS
2094700	ADAPTOR HP	23/02/11	P	S	P 0.09	P 49.14	P <0.05	P <0.10	PASS
2094701	FAN BUCHI AND Q	23/02/11	P	S	S	P 50.00	P <0.05	P <0.10	PASS
2094702	LEAD	23/02/11	P	P	P 0.10	P 50.00	S	S	PASS
2094703	MONITOR LCD FUJITSU SIEMENS	23/02/11	P	S	P 0.17	P 50.00	P <0.05	P 0.60	PASS
2094704	LEAD	23/02/11	P	P	P 0.07	P 49.08	S	S	PASS
2094705	ADAPTOR HP	23/02/11	P	S	P 0.08	P 49.02	P <0.05	P <0.10	PASS
2094706	LEAD	23/02/11	P	P	P 0.10	P 50.00	S	S	PASS
2094707	MONITOR LCD FUJITSU SIEMENS	23/02/11	P	S	P 0.20	P 50.00	P <0.05	P 0.60	PASS
2094708	LEAD	23/02/11	P	P	P 0.07	P 47.98	S	S	PASS
2094710	LEAD	23/02/11	P	P	P 0.10	P 50.00	S	S	PASS
2094711	MONITOR LCD FUJITSU SIEMENS	23/02/11	P	S	P 0.19	P 50.00	P <0.05	P 0.59	PASS
2094712	LEAD	23/02/11	P	P	P 0.06	P 48.67	S	S	PASS
2094713	ADAPTOR HP	23/02/11	P	S	P 0.07	P 49.06	P <0.05	P <0.10	PASS
2094714	LEAD	23/02/11	P	P	P 0.09	P 50.00	S	S	PASS
2094715	MONITOR LCD FUJITSU SIEMENS	23/02/11	P	S	P 0.16	P 50.00	P <0.05	P 0.61	PASS
2094716	LEAD	23/02/11	P	P	P 0.29	P 48.97	S	S	PASS
2094717	ADAPTOR HP	23/02/11	P	S	P 0.05	P 48.97	P <0.05	P <0.10	PASS
2094718	LEAD	23/02/11	P	P	P 0.10	P 50.00	S	S	PASS
2094719	MONITOR LCD FUJITSU SIEMENS	23/02/11	P	S	P 0.19	P 50.00	P <0.05	P 0.63	PASS
2094720	LEAD	23/02/11	P	P	P 0.06	P 48.89	S	S	PASS
2094722	EXTENSION LEAD 2 WAY	23/02/11	P	P	P 0.21	P 50.00	S	S	PASS
2094724	SHREDDER SWORDFISH	23/02/11	P	S	S	P 50.00	P <0.05	P <0.10	PASS
2094725	LEAD	23/02/11	P	P	P 0.37	P 50.00	S	S	PASS
2094726	MONITOR LCD FUJITSU SIEMENS	23/02/11	P	S	P 0.29	P 50.00	P <0.05	P 0.66	PASS
2094727	LEAD	23/02/11	P	P	P 0.09	P 50.00	S	S	PASS
2094729	LEAD	23/02/11	P	P	P 0.22	P 50.00	S	S	PASS
2094730	PRINTER HP	23/02/11	P	S	P 0.22	P 50.00	P 0.18	P 0.42	PASS
2094731	FAN	23/02/11	P	S	S	P 50.00	P <0.05	P <0.10	PASS
2094732	FAN BUCHI AND Q	23/02/11	P	S	S	P 50.00	P <0.05	P <0.10	PASS
2094745	PRINTER	23/02/11	F	S	S	S	S	S	FAIL
ASKED NOT TO REPAIR AS IT IS DUE TO BE REPLACED									
2094746	PHOTOCOPIER	23/02/11	F	S	S	S	S	S	FAIL
DAMAGED FLEX - REWIRE WITH NEW FLEX OR DISCARD									
ASKED NOT TO REPAIR AS DUE TO BE REPLACED									
2094747	TOASTER	23/02/11	P	S	P 0.00	F 0.00	S	P <0.10	FAIL
INSULATION RESISTANCE FAIL - SERVICE / REPAIR OR DISCARD									
Total Appliances >									<b>35</b>
<b>DONCASTER - OFFICE 1</b>									
2094667	EXTENSION LEAD 6 WAY	23/02/11	P	P	P 0.14	P 0.31	S	S	PASS
2094668	LEAD	23/02/11	P	P	P 0.12	P 50.00	S	S	PASS
2094669	MONITOR LCD SAMSUNG	23/02/11	P	S	P 0.19	P 50.00	P <0.05	P 0.16	PASS
2094670	LEAD	23/02/11	P	P	P 0.65	P 46.87	S	S	PASS

**APPLIANCE DETAILS AND TEST RESULTS**
**Key**

P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
2094672	SHREDDER REXEL	23/02/11	P	S	S	P 50.00	P <0.05	P <0.10	PASS
2094673	LEAD	23/02/11	P	P	P 0.10	P 50.00	S	S	PASS
2094674	PRINTER HP	23/02/11	P	S	P 0.24	P 50.00	P 0.21	P 0.41	PASS
2094743	MONITOR TANDBERG ASKED NOT TO DISCONNECT	23/02/11	P	S	S	S	S	S	PASS
2094749	LAMINATOR	23/02/11	P	S	P 0.00	P 2.00	S	P <0.10	PASS
Total Appliances >									<b>9</b>
<b>DONCASTER - OFFICE 2</b>									
2094675	LEAD	23/02/11	P	P	P 0.11	P 50.00	S	S	PASS
2094676	MONITOR LCD CTX	23/02/11	P	S	P 0.42	P 50.00	P <0.05	P 0.32	PASS
2094677	LEAD	23/02/11	P	P	P 0.20	P 50.00	S	S	PASS
2094679	LEAD	23/02/11	P	P	P 0.10	P 50.00	S	S	PASS
2094680	PRINTER HP	23/02/11	P	S	P 0.20	P 50.00	P 0.27	P 0.40	PASS
2094681	LAMP FIRSTLIGHT	23/02/11	P	S	S	P 50.00	P <0.05	P <0.10	PASS
2094682	AIR CONDITIONER	23/02/11	P	S	P 0.07	P 50.00	P 0.48	P 0.10	PASS
2094742	SERVER VISUAL TEST ONLY - COULD NOT SWITCH SERVER OFF	23/02/11	P	S	S	S	S	S	PASS
Total Appliances >									<b>8</b>
<b>DONCASTER - RECEPTION</b>									
2094683	LEAD	23/02/11	P	P	P 0.08	P 50.00	S	S	PASS
2094684	PHOTOCOPIER KONICA MINOLTA	23/02/11	P	S	P 0.10	P 50.00	P 0.09	P 0.29	PASS
2094686	PHONE CHARGER SONY	23/02/11	P	S	S	P 50.00	P <0.05	P <0.10	PASS
2094687	LEAD	23/02/11	P	P	P 0.10	P 50.00	S	S	PASS
2094690	LEAD	23/02/11	P	P	P 0.12	P 50.00	S	S	PASS
2094692	LEAD	23/02/11	P	P	P 0.11	P 50.00	S	S	PASS
2094693	PRINTER HP	23/02/11	P	S	P 0.24	P 50.00	P 0.37	P 0.41	PASS
2094694	HEATER PHILIPS	23/02/11	P	S	S	P 50.00	P 1.30	P <0.10	PASS
2094695	HEATER POWERLECTRIK	23/02/11	P	S	S	P 50.00	P 1.72	P <0.10	PASS
2094696	HEATER GLEN	23/02/11	P	S	S	P 50.00	P 1.49	P 0.16	PASS
2094744	ROATARY MOTOR DAMAGED FLEX - REWIRE WITH NEW FLEX OR DISCARD DISCARD.	23/02/11	F	S	S	S	S	S	FAIL
Total Appliances >									<b>11</b>
<b>DONCASTER - SERVER</b>									
2094733	NETGEAR ADAPTOR	23/02/11	P	S	S	P 50.00	P <0.05	P <0.10	PASS
2094735	PHONE CHARGER	23/02/11	P	S	S	P 50.00	P <0.05	P <0.10	PASS
2094736	NETGEAR ADAPTOR	23/02/11	P	S	S	P 50.00	P <0.05	P <0.10	PASS
2094739	NETGEAR ADAPTOR	23/02/11	P	S	S	P 50.00	P <0.05	P <0.10	PASS
2094741	SERVER VISUAL TEST ONLY - COULD NOT SWITCH SERVER OFF	23/02/11	P	S	S	S	S	S	PASS
Total Appliances >									<b>5</b>
<b>Total Appliances For Report:</b>									<b>84</b>