

Current Appliance
For all Sites and Locations

Mr Brown Joe
RSR Systems Ltd
Waterside House
Falmouth Road
Penryn
Cronwall
TR10 8BD
ron@simplypats.co.uk



SimplyPats PAT Testing Services
Waterside House
Falmouth Road
Penryn
Cornwall
TR10 8BD
Phone: 01326 378268
Mobile: 07775 000000
Email: support@simplypats.co.uk

For Appliance: E01079761

Appliance EXT CABLE 4 WAY
Appliance Id E01079761
Appliance SN 4555/EX

Overall Status: PASS

Class I Fuse Rating 13 Amps

Test Price Extension Lead

Site RSR SYSTEMS

Location GENERAL OFFICE

Test Date 05/11/2009 Time 11:48

Retest Date 05/11/2010 Retest Period 12

User R GARWOOD

PAT Serial No 010201/2424

Test Results

	Result	Limit	Output	Status	Fail Reason
Voltage					
Visual				P	
Polarity				P	
Continuity (Ohms)	0.12	0.00	0.00	P	
Insulation (M Ohms)	50.00	0.00	0.00	P	
Leak (mA)		0.00	0.00	S	Repair Description Qty
Touch Leak (mA)		0.00	0.00	S	Rewire existing plug
Sub Leak (mA)		0.00	0.00	S	Rewire a trailing socket
Flash (mA)		0.00	0.00	S	
Load (kVA)				S	Extra Notes
Clamp (mA)		0.00		S	REWIRE DUE TO LOOSE CABLE GRIPS.
Microwave (mW/cm2)	0.00				
RCD Trip Time (mS)	0.00				

Signed _____

Print Name _____