

Mr Brown Joe  
RSR Systems Ltd  
Waterside House  
Falmouth Road  
Penryn  
Cronwall  
TR10 8BD  
ron@simplypats.co.uk




SimplyPats PAT Testing Services  
Waterside House  
Falmouth Road  
Penryn  
Cornwall  
TR10 8BD  
Phone: 01326 378268  
Mobile: 07775 000000  
Email: support@simplypats.co.uk

RSR/0001



**Appliance Id**  
E02809975  
**Appliance**  
PAPER SHREDDER  
**Test Date:** 05/11/09  
**Status:** FAIL



**Appliance Id**  
E01079761  
**Appliance**  
EXT CABLE 4 WAY  
**Test Date:** 05/11/09  
**Status:** FAIL

SAFETY SWITCH FAULT, DISCARD.

VISUAL FAIL, CASING MELTED.



**Appliance Id**  
E01079756  
**Appliance**  
POWER LEAD  
**Test Date:** 05/11/09  
**Status:** FAIL



**Appliance Id**  
E01079759  
**Appliance**  
EXT CABLE 4 WAY  
**Test Date:** 05/11/09  
**Status:** FAIL

LIVE TERMINAL SCREW WELDED TO FUSE AND EARTH TERMINAL.

VISUAL FAIL, DISCARD, REPLACED WITH NEW UNIT.



**Appliance Id**  
E01079766  
**Appliance**  
KETTLE  
**Test Date:** 05/11/09  
**Status:** FAIL

NOT FUNCTIONAL, INTERMITTENT FAULT WITH SWITCH, DISCARD.