

Simplyfied Pass And Fails
For all Sites and Locations

Mr Brown Joe
RSR Systems Ltd
Waterside House
Falmouth Road
Penryn
Cronwall
TR10 8BD
ron@simplypats.co.uk



SimplyPats PAT Testing Services
Waterside House
Falmouth Road
Penryn
Cornwall
TR10 8BD
Phone: 01326 378268
Mobile: 07775 000000
Email: support@simplypats.co.uk

RSR/0001

App Id	Appliance Description	Test Date	Earth Cont Ohms	Insulation MOhms	Leakage mA	Load kVA	Result
MANAGER OFFICE							
E02920056	POWER LEAD	05/11/09					PASS
E02920055	PRINTER	05/11/09					PASS
E02809977	EXTENSION LEAD	05/11/09	0.15	50.00			PASS
E02809976	PHONE CHARGER	05/11/09		50.00			PASS
E02920057	POWER SUPPLY UNIT LAPTOP	05/11/09					PASS
E02809978	PEDESTAL FAN	05/11/09		50.00	<0.10	<0.05	PASS
E02809980	CONVECTOR HEATER	05/11/09	0.05	50.00	<0.10	1.92	PASS
E02920054	POWER LEAD	05/11/09					PASS
Total Appliances:							8
OFFICE 3							
E01079777	CONVECTOR HEATER	05/11/09	0.08	50.00	<0.10	1.83	PASS
E01079778	LAMP	05/11/09		50.00	<0.10	<0.05	PASS
E02012544	RADIO FLEX	05/11/09		50.00			PASS
E01079776	LAMP	05/11/09		50.00	<0.10	<0.05	PASS
E02012545	RADIO CD PLAYER	05/11/09		50.00	<0.10	<0.05	PASS
Total Appliances:							5
1ST FLOOR KITCHEN							
E02012561	KETTLE FLEX	05/11/09	0.05	50.00			PASS
E02012564	KETTLE BASE	05/11/09	0.06	50.00			PASS
E01079762	TOASTER	05/11/09	0.07	50.00	<0.10	0.92	PASS
E02012565	KETTLE	05/11/09	0.05	50.00	<0.10	1.98	PASS
E02012563	FRIDGE	05/11/09	0.09	50.00	<0.10	0.08	PASS
E02012562	MICROWAVE	05/11/09	0.05	50.00	<0.10	1.89	PASS
E02012566	SANDWICH TOASTER	05/11/09	0.06	50.00	<0.10	0.67	PASS
E02920117	MICROWAVE	05/11/09	0.06	50.00	<0.10	1.96	PASS
Total Appliances:							8
1ST FLOOR OFFICES							
E02012558	BATTERY CHARGER PHONE	05/11/09		50.00	<0.10	<0.05	PASS
E02012559	POWER LEAD	05/11/09	0.06	50.00			PASS
E01079752	TRAILING SOCKET	05/11/09	0.10	50.00			PASS
E01079751	POWER SUPPLY	05/11/09		50.00	<0.10	<0.05	PASS
E01079749	LAMP	05/11/09		50.00	<0.10	<0.05	PASS
E01079750	LAMP	05/11/09		50.00	<0.10	<0.05	PASS
E02012560	WATER TOWER	05/11/09	0.09	50.00	<0.10	<0.05	PASS
E01079754	LAMINATOR	05/11/09		50.00	<0.10	0.32	PASS
E01079755	DESK FAN	05/11/09	0.12	50.00	<0.10	0.06	PASS
E02012555	BATTERY CHARGER PHONE	05/11/09		50.00	<0.10	<0.05	PASS
E01079742	RADIO FLEX	05/11/09		50.00			PASS
E02012557	RADIATOR	05/11/09	0.07	50.00	<0.10	0.38	PASS
E02012556	RADIO CD PLAYER	05/11/09		50.00	<0.10	<0.05	PASS
Total Appliances:							13

App Id	Appliance Description	Test Date	Earth Cont Ohms	Insulation MOhms	Leakage mA	Load kVA	Result
ADMIN OFFICE							
E02807605	POWER LEAD	05/11/09					PASS
E02920045	COMPUTER	05/11/09					PASS
E02376000	POWER LEAD	05/11/09					PASS
E02920049	FAX	05/11/09					PASS
E02375998	POWER LEAD	05/11/09					PASS
E02920048	PRINTER	05/11/09					PASS
E02375999	POWER LEAD	05/11/09					PASS
E02920047	PRINTER	05/11/09					PASS
E02920046	V.D.U. MONITOR	05/11/09					PASS
E02809971	DICTAPHONE	05/11/09		50.00	<0.10	<0.05	PASS
E02375997	POWER LEAD	05/11/09					PASS
E02809972	ANSWER PHONE	05/11/09					PASS
E02809973	DESK FAN	05/11/09	0.13	50.00	<0.10	<0.05	PASS
E02809974	FAN HEATER	05/11/09		50.00	<0.10	1.77	PASS
E02920050	POWER LEAD	05/11/09					PASS
E02809975	PAPER SHREDDER	05/11/09	0.02	50.00	<0.10	0.10	PASS
E02920051	POWER LEAD	05/11/09					PASS
E02807604	RCD	05/11/09					PASS
E02920052	COMPUTER	05/11/09					PASS
E02920053	V.D.U. MONITOR	05/11/09					PASS
E02809959	POWER LEAD	05/11/09		50.00	<0.10	<0.05	PASS
Total Appliances:							21
CLEANER S CUPBOARD							
E02807606	VACUUM CLEANER	05/11/09		50.00	<0.10	0.83	PASS
E02809979	VACUUM CLEANER	05/11/09		50.00	<0.10	1.02	PASS
Total Appliances:							2
CORRIDOR							
E02809969	WATER COOLER	05/11/09	0.08	50.00	<0.10	<0.05	PASS
E02807603	PHOTOCOPIER	05/11/09					PASS
Total Appliances:							2
DEVELOPERS OFFICE							
E02920120	V.D.U. MONITOR	05/11/09					PASS
E02920116	PHONE CHARGER	05/11/09		50.00			PASS
E02920119	COMPUTER	05/11/09					PASS
E02920123	POWER LEAD CISCO1800	05/11/09					PASS
E02920103	POWER LEAD	05/11/09					PASS
E02920121	POWER LEAD COMMS CABINET	05/11/09					PASS
E02920115	PHONE CHARGER	05/11/09		50.00			PASS
E02920104	POWER LEAD	05/11/09					PASS
E02920122	POWER LEAD CISCO2800	05/11/09					PASS
E02920102	V.D.U. MONITOR	05/11/09					PASS
E02920101	COMPUTER	05/11/09					PASS
E02920100	POWER LEAD	05/11/09					PASS
Total Appliances:							12
FILING ROOM							
E02809993	PEDESTAL FAN	05/11/09	0.18	50.00	<0.10	<0.05	PASS
E02809992	PEDESTAL FAN	05/11/09		50.00	<0.10	<0.05	PASS
E02809991	PEDESTAL FAN	05/11/09	0.13	50.00	<0.10	<0.05	PASS
Total Appliances:							3

App Id	Appliance Description	Test Date	Earth Cont Ohms	Insulation MOhms	Leakage mA	Load kVA	Result
GENERAL OFFICE							
E01079764	FRIDGE	05/11/09	0.01	50.00	<0.10	<0.05	PASS
E01079761	EXT CABLE 4 WAY	05/11/09	0.12	50.00			PASS
E01079744	POWER LEAD	05/11/09	0.09	50.00			PASS
E01079746	PRINTER	05/11/09	0.01	50.00	0.18	<0.05	PASS
E01079745	POWER LEAD	05/11/09	0.09	50.00			PASS
E01079757	POWER LEAD	05/11/09	0.08	50.00			PASS
E01079753	AC ADAPTOR	05/11/09		50.00	<0.10	<0.05	PASS
E01079760	PRINTER	05/11/09		9.52	0.12	<0.05	PASS
E01079756	POWER LEAD	05/11/09	0.08	50.00			FAIL
E01079759	MONITOR	05/11/09	0.01	50.00	0.51	<0.05	PASS
E01079763	MICROWAVE	05/11/09	0.01	50.00	0.23	1.01	PASS
E01079747	COMPUTER	05/11/09	0.01	50.00	0.36	<0.05	PASS
E01079748	MONITOR	05/11/09	0.01	50.00	0.44	<0.05	PASS
E01079758	COMPUTER	05/11/09	0.01	50.00	0.46	<0.05	PASS
Total Appliances:							14
GRD FLOOR KITCHEN							
E02809968	KETTLE	05/11/09	0.05	50.00	<0.10	2.08	PASS
Total Appliances:							1
GROUND FLOOR							
E02012546	LAMP	05/11/09		50.00	<0.10	<0.05	PASS
E02012549	WATER TOWER	05/11/09	0.08	50.00	<0.10	<0.05	PASS
E02012548	POWER LEAD	05/11/09	0.06	50.00			PASS
E02012547	PHOTOCOPIER	05/11/09	0.09	50.00	0.47	0.08	PASS
Total Appliances:							4
GROUND FLOOR KITCHEN							
E01079766	KETTLE	05/11/09	0.04	50.00	<0.10	2.10	PASS
E01079765	KETTLE FLEX	05/11/09	0.03	50.00			PASS
E01079767	FRIDGE	05/11/09	0.10	50.00	<0.10	0.15	PASS
E01079768	MICROWAVE OVEN	05/11/09	0.05	50.00	0.11	1.36	PASS
Total Appliances:							4

App Id	Appliance Description	Test Date	Earth Cont Ohms	Insulation MOhms	Leakage mA	Load kVA	Result
MAIN OFFICE							
E02920093	POWER LEAD	05/11/09					PASS
E02920108	PHONE CHARGER	05/11/09		50.00			PASS
E02920114	EXTENSION LEAD	05/11/09	0.69				PASS
E01079740	MONITOR	05/11/09	0.03	50.00	0.28	<0.05	PASS
E02920091	POWER LEAD	05/11/09					PASS
E02809999	RADIO CASS. FLEX	05/11/09		50.00			PASS
E02920095	COMPUTER	05/11/09					PASS
E02920099	POWER SUPPLY UNIT ROUTER	05/11/09					PASS
E02920092	POWER LEAD	05/11/09					PASS
E02920076	PRINTER	05/11/09					PASS
E02920096	COMPUTER	05/11/09					PASS
E02920097	V.D.U. MONITOR	05/11/09					PASS
E02920098	V.D.U. MONITOR	05/11/09					PASS
E01079739	POWER LEAD	05/11/09	0.05	50.00			PASS
E02920105	POWER LEAD	05/11/09	0.04	50.00			PASS
E02920094	POWER LEAD	05/11/09					PASS
E02920112	LUMINAIRE	05/11/09		50.00	<0.10	<0.05	PASS
E02920113	PHONE CHARGER	05/11/09		50.00			PASS
E01079738	POWER LEAD	05/11/09	0.05	50.00			PASS
E02810000	RADIO	05/11/09		50.00	<0.10	<0.05	PASS
E02920110	PHONE CHARGER	05/11/09		50.00			PASS
E02920107	XMAS LAMP	05/11/09		50.00	<0.10	<0.05	PASS
E02920089	POWER LEAD	05/11/09					PASS
E02920106	FAN HEATER	05/11/09		50.00	<0.10	1.04	PASS
E02920090	PRINTER	05/11/09					PASS
E02920111	PAPER SHREDDER	05/11/09	0.02	50.00	<0.10	0.10	PASS
E02920081	V.D.U. MONITOR	05/11/09					PASS
E02920077	POWER LEAD	05/11/09					PASS
E02920084	POWER LEAD	05/11/09					PASS
E02920086	COMPUTER	05/11/09					PASS
E02920079	COMPUTER	05/11/09					PASS
E02920080	COMPUTER	05/11/09					PASS
E02920087	V.D.U. MONITOR	05/11/09					PASS
E02920083	POWER LEAD	05/11/09					PASS
E02809998	PHONE CHARGER	05/11/09		50.00			PASS
E02920082	V.D.U. MONITOR	05/11/09					PASS
E02920074	FAX	05/11/09					PASS
E02920085	COMPUTER	05/11/09					PASS
E02920078	POWER LEAD	05/11/09					PASS
E02809996	WATER COOLER	05/11/09	0.12	50.00	<0.10	0.13	PASS
E02920071	POWER LEAD	05/11/09					PASS
E02920072	POWER LEAD	05/11/09					PASS
E02920109	PEDESTAL FAN	05/11/09	0.11	50.00	<0.10	<0.05	PASS
E02920088	V.D.U. MONITOR	05/11/09					PASS
E02809995	POWER LEAD	05/11/09	0.13	50.00			PASS
E02920073	POWER LEAD	05/11/09					PASS
E01079743	POWER LEAD	05/11/09	0.09	50.00			PASS
E01079737	PRINTER	05/11/09		50.00	<0.10	<0.05	PASS
E01079741	COMPUTER	05/11/09	0.03	50.00	0.48	<0.05	PASS
E02920075	PRINTER	05/11/09					PASS
E02809994	EXTENSION LEAD	05/11/09	0.17				PASS
E02809997	PHONE CHARGER	05/11/09		50.00			PASS

Total Appliances: 52

App Id	Appliance Description	Test Date	Earth Cont Ohms	Insulation MOhms	Leakage mA	Load kVA	Result
OFFICE 2							
E02809989	DESK FAN	05/11/09	0.15	50.00	<0.10	<0.05	PASS
E02809988	PEDESTAL FAN	05/11/09		50.00	<0.10	<0.05	PASS
E02809986	WATER COOLER	05/11/09	0.09	50.00	<0.10	<0.05	PASS
E02920066	POWER LEAD	05/11/09					PASS
E02920065	POWER LEAD	05/11/09					PASS
E02809990	EXTENSION LEAD	05/11/09	0.14	50.00			PASS
E02920070	V.D.U. MONITOR	05/11/09					PASS
E02920067	RCD	05/11/09					PASS
E02920068	PRINTER	05/11/09					PASS
E02809985	FIBRE OPTIC TREE	05/11/09		50.00	<0.10	<0.05	PASS
E02920069	COMPUTER	05/11/09					PASS
E02809987	PEDESTAL FAN	05/11/09		50.00	<0.10	<0.05	PASS
Total Appliances:							12
RECEPTION							
E01079784	PRINTER	05/11/09		50.00	<0.10	<0.05	PASS
E01079783	RCD	05/11/09					PASS
E01079787	MONITOR	05/11/09	0.01	50.00	0.64	<0.05	PASS
E01079788	COMPUTER	05/11/09	0.01	50.00	0.73	<0.05	PASS
E01079786	POWER LEAD	05/11/09					PASS
E01079785	POWER LEAD	05/11/09					PASS
Total Appliances:							6
RECEPTION OFFICE							
E01079780	LAMP	05/11/09		50.00	<0.10	0.14	PASS
E01079782	ANSWERPHONE	05/11/09					PASS
E01079781	FAX MACHINE	05/11/09	0.02	50.00	0.12	<0.05	PASS
E01079779	PAPER SHREDDER	05/11/09	0.08	50.00	<0.10	0.40	PASS
E02012543	POWER SUPPLY NETWORK	05/11/09		50.00	<0.10	<0.05	PASS
E02012542	BATTERY CHARGER PHONE	05/11/09		50.00	<0.10	<0.05	PASS
Total Appliances:							6
REST ROOM							
E02809958	PEDESTAL FAN	05/11/09	0.11	50.00	<0.10	<0.05	PASS
E01079769	LUMINAIRE	05/11/09		50.00	<0.10	<0.05	PASS
E02809957	LUMINAIRE	05/11/09		50.00	<0.10	0.13	PASS
E02809956	FRIDGE	05/11/09	0.13	50.00	<0.10	<0.05	PASS
E01079770	FRIDGE	05/11/09	0.08	50.00	<0.10	0.16	PASS
Total Appliances:							5
TESTING TEAM OFFICE							
E02920059	COMPUTER	05/11/09					PASS
E02920058	POWER LEAD	05/11/09					PASS
E02920060	V.D.U. MONITOR	05/11/09					PASS
E02920061	POWER LEAD	05/11/09					PASS
E02809984	PHONE CHARGER	05/11/09		50.00			PASS
E02920063	POWER LEAD	05/11/09					PASS
E02809981	PHONE CHARGER	05/11/09		50.00			PASS
E02809982	PHONE CHARGER	05/11/09		50.00			PASS
E02809983	PAPER SHREDDER	05/11/09		50.00	<0.10	0.07	PASS
E02920062	POWER SUPPLY UNIT LAPTOP	05/11/09					PASS
Total Appliances:							10
TRAINING ROOM							
E01079773	PORTABLE TELEVISION	05/11/09		50.00	<0.10	<0.05	PASS
E02012552	POWER LEAD	05/11/09		50.00			PASS
E01079772	VIDEO RECORDER	05/11/09		50.00	<0.10	<0.05	PASS
E02012553	TELEVISION	05/11/09		50.00	<0.10	<0.05	PASS
E01079774	POWER SUPPLY	05/11/09		50.00	<0.10	<0.05	PASS
E01079771	OVERHEAD PROJECTOR	05/11/09	0.15	50.00	<0.10	0.09	PASS
E02807607	POWER LEAD	05/11/09	0.11	50.00			PASS
E01079775	LUMINAIRE	05/11/09		50.00	<0.10	<0.05	FAIL
E02809970	VIDEO RECORDER	05/11/09		50.00	<0.10	<0.05	PASS
E02012551	PORTABLE TELEVISION	05/11/09		50.00	<0.10	<0.05	PASS
E02012550	LAMP	05/11/09		50.00	<0.10	0.05	PASS
E02012554	POWER LEAD	05/11/09	0.11	50.00			FAIL
Total Appliances:							12

App Id	Appliance Description	Test Date	Earth Cont Ohms	Insulation MOhms	Leakage mA	Load kVA	Result
---------------	------------------------------	------------------	--------------------------------	-----------------------------	-----------------------	---------------------	---------------

Total Appliances For Report: 200